

252185-2026 - Mise en concurrence

Irlande – Services d'installation de matériel de protection contre l'incendie – Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26

OJ S 72/2026 14/04/2026

Avis de marché – régime assoupli

Services

1. Acheteur

1.1. Acheteur

Nom officiel: Medite Europe DAC

Adresse électronique: John.Browne@mdfosb.com

Forme juridique de l'acheteur: Entité disposant de droits spéciaux ou exclusifs

2. Procédure

2.1. Procédure

Titre: Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26

Description: MEDITE Europe DAC are looking for suitably qualified Fire suppression companies to install suppression systems in the following Motor Control Centre (MCC) rooms across the Medite plant. • Anner HV Sub-Station • Fire-Pump House MCC • Line1 post-press MCC Project Background Mandatory Insurance Requirement Medite electrical distribution network comprises 17 Motor Control Centre rooms, and the main HV Switch-room located at Anner Substation. (See MCC layout drawing in Appendix 3). A number of these MCCs and the main Switch-room are considered higher impact and risk, due to the criticality of the processes they support and the ageing condition of the installed switchgear and associated cooling systems. Overall Program Objectives The multi-year goal of this program is to ensure that all site MCC + HV switch-room comply with legislative requirements and industry best practice for extinguishing electrical fires automatically. It is proposed to install a similar Clean Agent gaseous suppression system with appropriate smoke detection in all MCC rooms, starting with those with critical switchgear. Program estimated to take ~4 years. The program scope includes: • Design of suppression system for each room considering: Size and fabric of structure Presence of a floor void(s) or not Age + condition of switchgear (risk of overheating + fire) Ability to seal room effectively * Type of cooling + air-handling (AHU) in place Characterization of pressure in room now – Positive or Negative ** Ability to locate pressurized cylinders nearby • All necessary civil, mechanical and electrical (pre)works to enable the chosen system(s) • Integration of each system's controls into the existing plant fire alarm system, where applicable to deliver the project goals • Ensure compatibility of control system with existing ones (fire control panel) * for total flood systems ** most Medite MCCs are positive pressure to keep out dust As part of the 2026 program of works the following 3 electrical rooms are to be addressed: • Anner Sub-station switch-room • Fire Pumphouse MCC room • Line1 Press Outfeed MCC room Preferred route is to install an Inert Gas system with appropriate Smoke Detection system. Scope of Works • Evaluate Enclosure Integrity Test results ('door-fan' test report) • Determine existing baseline for cooling, air-handling + room pressure profile • Based on results of EIT report referenced in Appendix 3, recommend and execute remedial measures • Determine and design optimal suppression system • Design and

specify all necessary smoke / heat detection systems • Fire seal room to appropriate fire-rate • Install fire detection system • Install suppression system • Link system to house alarm and test • Validate and certify finished system *** Please see the attached Tender Document for the full and Complete scope of Works ***

Identifiant de la procédure: 2ed6a4a4-39bf-4f6e-b409-dbacf6d7d837

Type de procédure: Ouverte

Principales caractéristiques de la procédure et informations sur l'endroit où obtenir les règles complètes applicables à la procédure: Tender Document attached

2.1.1. Objet

Nature principale du marché: Services

Nomenclature principale (cpv): 51700000 Services d'installation de matériel de protection contre l'incendie

Nomenclature complémentaire (cpv): 45343000 Travaux d'installation de dispositifs de prévention contre les incendies, 35111500 Système d'extinction d'incendie, 45312100 Travaux d'installation de systèmes avertisseurs d'incendie, 45343200 Travaux d'installation de dispositifs d'extinction d'incendie, 31625100 Systèmes de détection d'incendie, 31625200 Systèmes d'alarme incendie, 44482000 Dispositifs de protection contre l'incendie

2.1.2. Lieu d'exécution

Subdivision pays (NUTS): South-East (IE052)

Pays: Irlande

2.1.3. Valeur

Valeur estimée hors TVA: 165 000,00 EUR

2.1.4. Informations générales

Base juridique:

Directive 2014/24/UE

2.1.6. Motifs d'exclusion

Sources des motifs d'exclusion: Document de marché

5. Lot

5.1. Lot: LOT-0001

Titre: Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26

Description: MEDITE Europe DAC are looking for suitably qualified Fire suppression companies to install suppression systems in the following Motor Control Centre (MCC) rooms across the Medite plant. • Anner HV Sub-Station • Fire-Pump House MCC • Line1 post-press MCC Project Background Mandatory Insurance Requirement Medite electrical distribution network comprises 17 Motor Control Centre rooms, and the main HV Switch-room located at Anner Substation. (See MCC layout drawing in Appendix 3). A number of these MCCs and the main Switch-room are considered higher impact and risk, due to the criticality of the processes they support and the ageing condition of the installed switchgear and associated cooling systems. Overall Program Objectives The multi-year goal of this program is to ensure that all site MCC + HV switch-room comply with legislative requirements and industry best practice for extinguishing electrical fires automatically. It is proposed to install a similar Clean Agent gaseous suppression system with appropriate smoke detection in all MCC rooms, starting with those with critical switchgear. Program estimated to take ~4 years. The program scope includes: • Design of suppression system for each room considering: Size and fabric of

structure Presence of a floor void(s) or not Age + condition of switchgear (risk of overheating + fire) Ability to seal room effectively * Type of cooling + air-handling (AHU) in place Characterization of pressure in room now – Positive or Negative ** Ability to locate pressurized cylinders nearby • All necessary civil, mechanical and electrical (pre)works to enable the chosen system(s) • Integration of each system's controls into the existing plant fire alarm system, where applicable to deliver the project goals • Ensure compatibility of control system with existing ones (fire control panel) * for total flood systems ** most Medite MCCs are positive pressure to keep out dust As part of the 2026 program of works the following 3 electrical rooms are to be addressed: • Anner Sub-station switch-room • Fire Pumphouse MCC room • Line1 Press Outfeed MCC room Preferred route is to install an Inert Gas system with appropriate Smoke Detection system. Scope of Works • Evaluate Enclosure Integrity Test results ('door-fan' test report) • Determine existing baseline for cooling, air-handling + room pressure profile • Based on results of EIT report referenced in Appendix 3, recommend and execute remedial measures • Determine and design optimal suppression system • Design and specify all necessary smoke / heat detection systems • Fire seal room to appropriate fire-rate • Install fire detection system • Install suppression system • Link system to house alarm and test • Validate and certify finished system *** Please see the attached Tender Document for the full and Complete scope of Works ***

Identifiant interne: 0

5.1.1. **Objet**

Nature principale du marché: Services

Nomenclature principale (cpv): 51700000 Services d'installation de matériel de protection contre l'incendie

Nomenclature complémentaire (cpv): 45343000 Travaux d'installation de dispositifs de prévention contre les incendies, 35111500 Système d'extinction d'incendie, 45312100 Travaux d'installation de systèmes avertisseurs d'incendie, 45343200 Travaux d'installation de dispositifs d'extinction d'incendie, 31625100 Systèmes de détection d'incendie, 31625200 Systèmes d'alarme incendie, 44482000 Dispositifs de protection contre l'incendie

5.1.2. **Lieu d'exécution**

Subdivision pays (NUTS): South-East (IE052)

Pays: Irlande

5.1.3. **Durée estimée**

Durée: 1 Mois

5.1.5. **Valeur**

Valeur estimée hors TVA: 165 000,00 EUR

5.1.6. **Informations générales**

Participation réservée:

La participation n'est pas réservée.

Projet de passation de marché non financé par des fonds de l'UE

5.1.7. **Marché public stratégique**

Objectif du marché public stratégique: Pas de passation de marché stratégique

5.1.9. **Critères de sélection**

Sources des critères de sélection: Document de marché

5.1.11. **Documents de marché**

Langues dans lesquelles les documents de marché sont officiellement disponibles: anglais

Langues dans lesquelles les documents de marché (ou des parties de ceux-ci) sont officiellement disponibles: anglais

Date limite de demande d'informations complémentaires: 24/04/2026 15:00:00 (UTC+01:00)

Heure de l'Europe centrale, heure d'été de l'Europe occidentale

Adresse des documents de marché: <https://www.etenders.gov.ie/epps/cft/listContractDocuments.do?resourceId=7885524>

5.1.12. Conditions du marché public

Conditions de soumission:

Soumission par voie électronique: Requise

Adresse de soumission: <https://www.etenders.gov.ie/epps/cft/viewTenders.do?resourceId=7885524>

Langues dans lesquelles les offres ou demandes de participation/candidatures peuvent être présentées: anglais

Catalogue électronique: Non autorisée

Les soumissionnaires peuvent présenter plusieurs offres: Non autorisée

Date limite de réception des offres: 01/05/2026 15:00:00 (UTC+01:00) Heure de l'Europe centrale, heure d'été de l'Europe occidentale

Informations relatives à l'ouverture publique:

Date d'ouverture: 01/05/2026 15:30:00 (UTC+01:00) Heure de l'Europe centrale, heure d'été de l'Europe occidentale

Lieu: <https://www.etenders.gov.ie/epps/cft/prepareViewCfTWS.do?resourceId=7885524>

Conditions du marché:

Le contrat doit être exécuté dans le cadre de programmes d'emplois protégés: Non

5.1.15. Techniques

Accord-cadre:

Pas d'accord-cadre

Informations sur le système d'acquisition dynamique:

Pas de système d'acquisition dynamique

5.1.16. Informations complémentaires, médiation et recours

Organisation chargée des procédures de recours: The High Court of Ireland

Organisation qui fournit un accès hors ligne aux documents de marché: Medite Europe DAC

Organisation qui fournit des précisions concernant l'introduction des recours: The High Court of Ireland

Organisation qui reçoit les demandes de participation/candidatures: Medite Europe DAC

Organisation qui traite les offres: Medite Europe DAC

8. Organisations

8.1. ORG-0001

Nom officiel: Medite Europe DAC

Numéro d'enregistrement: 80984

Adresse postale: Redmondstown

Ville: Clonmel

Code postal: E91V584

Subdivision pays (NUTS): South-East (IE052)

Pays: Irlande

Adresse électronique: John.Browne@mdfosb.com

Téléphone: 051831427

Profil de l'acheteur: www.etenders.gov.ie

Rôles de cette organisation:

Acheteur

Organisation qui fournit un accès hors ligne aux documents de marché

Organisation qui reçoit les demandes de participation/candidatures

Organisation qui traite les offres

8.1. ORG-0002

Nom officiel: The High Court of Ireland

Numéro d'enregistrement: The High Court of Ireland

Département: The High Court of Ireland

Adresse postale: Four Courts, Inns Quay, Dublin 7

Ville: Dublin

Code postal: D07 WDX8

Subdivision pays (NUTS): Dublin (IE061)

Pays: Irlande

Adresse électronique: HighCourtCentralOffice@courts.ie

Téléphone: +353 1 8886000

Rôles de cette organisation:

Organisation chargée des procédures de recours

Organisation qui fournit des précisions concernant l'introduction des recours

8.1. ORG-0003

Nom officiel: European Dynamics S.A.

Numéro d'enregistrement: 002024901000

Département: European Dynamics S.A.

Ville: Athens

Code postal: 15125

Subdivision pays (NUTS): Βόρειος Τομέας Αθηνών (EL301)

Pays: Grèce

Adresse électronique: eproc-esender@eurodyn.com

Téléphone: +30 2108094500

Rôles de cette organisation:

TED eSender

Informations relatives à l'avis

Identifiant/version de l'avis: 64611b95-7ea7-45c3-b367-8d428a2988f7 - 01

Type de formulaire: Mise en concurrence

Type d'avis: Avis de marché – régime assoupli

Sous-type d'avis: 20

Date d'envoi de l'avis: 10/04/2026 15:46:45 (UTC+01:00) Heure de l'Europe centrale, heure d'été de l'Europe occidentale

Langues dans lesquelles l'avis en question est officiellement disponible: anglais

Numéro de publication de l'avis: 252185-2026

Numéro de publication au JO S: 72/2026

Date de publication: 14/04/2026