

## 252185-2026 - Concurso

**Irlanda – Serviços de instalação de equipamento de protecção contra incêndios – Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26**

**OJ S 72/2026 14/04/2026**

**Anúncio de concurso — regime simplificado**

**Serviços**

### 1. Adquirente

---

#### 1.1. Adquirente

Nome oficial: Medite Europe DAC

Correio eletrónico: [John.Browne@mdfosb.com](mailto:John.Browne@mdfosb.com)

Forma jurídica do adquirente: Entidade com direitos especiais ou exclusivos

### 2. Procedimento

---

#### 2.1. Procedimento

**Título:** Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26

**Descrição:** MEDITE Europe DAC are looking for suitably qualified Fire suppression companies to install suppression systems in the following Motor Control Centre (MCC) rooms across the Medite plant. • Anner HV Sub-Station • Fire-Pump House MCC • Line1 post-press MCC

**Project Background** Mandatory Insurance Requirement Medite electrical distribution network comprises 17 Motor Control Centre rooms, and the main HV Switch-room located at Anner Substation. (See MCC layout drawing in Appendix 3). A number of these MCCs and the main Switch-room are considered higher impact and risk, due to the criticality of the processes they support and the ageing condition of the installed switchgear and associated cooling systems.

**Overall Program Objectives** The multi-year goal of this program is to ensure that all site MCC + HV switch-room comply with legislative requirements and industry best practice for extinguishing electrical fires automatically. It is proposed to install a similar Clean Agent gaseous suppression system with appropriate smoke detection in all MCC rooms, starting with those with critical switchgear. Program estimated to take ~4 years. The program scope includes:

- Design of suppression system for each room considering: Size and fabric of structure Presence of a floor void(s) or not Age + condition of switchgear (risk of overheating + fire) Ability to seal room effectively \*
- Type of cooling + air-handling (AHU) in place
- Characterization of pressure in room now – Positive or Negative \*\* Ability to locate pressurized cylinders nearby
- All necessary civil, mechanical and electrical (pre)works to enable the chosen system(s)
- Integration of each system's controls into the existing plant fire alarm system, where applicable to deliver the project goals
- Ensure compatibility of control system with existing ones (fire control panel) \*
- for total flood systems \*\* most Medite MCCs are positive pressure to keep out dust

As part of the 2026 program of works the following 3 electrical rooms are to be addressed: • Anner Sub-station switch-room • Fire Pumphouse MCC room • Line1 Press Outfeed MCC room Preferred route is to install an Inert Gas system with appropriate Smoke Detection system.

**Scope of Works**

- Evaluate Enclosure Integrity Test results ('door-fan' test report)
- Determine existing baseline for cooling, air-handling + room pressure profile
- Based on results of EIT report referenced in Appendix 3, recommend and execute remedial measures
- Determine and design optimal suppression system
- Design and

specify all necessary smoke / heat detection systems • Fire seal room to appropriate fire-rate • Install fire detection system • Install suppression system • Link system to house alarm and test • Validate and certify finished system \*\*\* Please see the attached Tender Document for the full and Complete scope of Works \*\*\*

Identificador do procedimento: 2ed6a4a4-39bf-4f6e-b409-dbacf6d7d837

Tipo de procedimento: Aberto

Principais características do processo: Tender Document attached

#### 2.1.1. Finalidade

Natureza do contrato: Serviços

Classificação principal (cpv): 51700000 Serviços de instalação de equipamento de protecção contra incêndios

Classificação adicional (cpv): 45343000 Instalação de equipamento para prevenção de incêndios, 35111500 Sistema de supressão de incêndios, 45312100 Instalação de sistemas de alarme contra incêndio, 45343200 Instalação de equipamento de combate a incêndios, 31625100 Sistemas de detecção de incêndios, 31625200 Sistemas de alarme contra incêndios, 44482000 Dispositivos de protecção contra incêndios

#### 2.1.2. Local de execução

Subdivisão do país (NUTS): South-East (IE052)

País: Irlanda

#### 2.1.3. Valor

Valor estimado, sem IVA: 165 000,00 EUR

#### 2.1.4. Informações gerais

**Base jurídica:**

Diretiva 2014/24/UE

#### 2.1.6. Motivos de exclusão

Fontes dos motivos de exclusão: Documento do concurso

## 5. Lote

---

### 5.1. Lote: LOT-0001

Título: Tender for the Design, Supply and Installation of Fire Extinguishing (Suppression) Systems in 3 MCC Rooms at MEDITE Europe DAC '26

Descrição: MEDITE Europe DAC are looking for suitably qualified Fire suppression companies to install suppression systems in the following Motor Control Centre (MCC) rooms across the Medite plant. • Anner HV Sub-Station • Fire-Pump House MCC • Line1 post-press MCC  
Project Background Mandatory Insurance Requirement Medite electrical distribution network comprises 17 Motor Control Centre rooms, and the main HV Switch-room located at Anner Substation. (See MCC layout drawing in Appendix 3). A number of these MCCs and the main Switch-room are considered higher impact and risk, due to the criticality of the processes they support and the ageing condition of the installed switchgear and associated cooling systems.  
Overall Program Objectives The multi-year goal of this program is to ensure that all site MCC + HV switch-room comply with legislative requirements and industry best practice for extinguishing electrical fires automatically. It is proposed to install a similar Clean Agent gaseous suppression system with appropriate smoke detection in all MCC rooms, starting with those with critical switchgear. Program estimated to take ~4 years. The program scope includes: • Design of suppression system for each room considering: Size and fabric of structure Presence of a floor void(s) or not Age + condition of switchgear (risk of overheating

+ fire) Ability to seal room effectively \* Type of cooling + air-handling (AHU) in place  
 Characterization of pressure in room now – Positive or Negative \*\* Ability to locate  
 pressurized cylinders nearby • All necessary civil, mechanical and electrical (pre)works to  
 enable the chosen system(s) • Integration of each system's controls into the existing plant fire  
 alarm system, where applicable to deliver the project goals • Ensure compatibility of control  
 system with existing ones (fire control panel) \* for total flood systems \*\* most Medite MCCs  
 are positive pressure to keep out dust As part of the 2026 program of works the following 3  
 electrical rooms are to be addressed: • Anner Sub-station switch-room • Fire Pumphouse MCC  
 room • Line1 Press Outfeed MCC room Preferred route is to install an Inert Gas system with  
 appropriate Smoke Detection system. Scope of Works • Evaluate Enclosure Integrity Test  
 results ('door-fan' test report) • Determine existing baseline for cooling, air-handling + room  
 pressure profile • Based on results of EIT report referenced in Appendix 3, recommend and  
 execute remedial measures • Determine and design optimal suppression system • Design and  
 specify all necessary smoke / heat detection systems • Fire seal room to appropriate fire-rate •  
 Install fire detection system • Install suppression system • Link system to house alarm and test  
 • Validate and certify finished system \*\*\* Please see the attached Tender Document for the full  
 and Complete scope of Works \*\*\*  
 Identificador interno: 0

#### **5.1.1. Finalidade**

Natureza do contrato: Serviços

Classificação principal (cpv): 51700000 Serviços de instalação de equipamento de protecção  
 contra incêndios

Classificação adicional (cpv): 45343000 Instalação de equipamento para prevenção de  
 incêndios, 35111500 Sistema de supressão de incêndios, 45312100 Instalação de sistemas  
 de alarme contra incêndio, 45343200 Instalação de equipamento de combate a incêndios,  
 31625100 Sistemas de detecção de incêndios, 31625200 Sistemas de alarme contra incêndios  
 , 44482000 Dispositivos de protecção contra incêndios

#### **5.1.2. Local de execução**

Subdivisão do país (NUTS): South-East (IE052)

País: Irlanda

#### **5.1.3. Duração estimada**

Duração: 1 Mês

#### **5.1.5. Valor**

Valor estimado, sem IVA: 165 000,00 EUR

#### **5.1.6. Informações gerais**

##### **Participação reservada:**

A participação não está reservada.

Projeto de contratação pública não financiado por fundos da UE

#### **5.1.7. Contratação estratégica**

Objetivo da contratação estratégica: Inexistência de contratação pública estratégica

#### **5.1.9. Critérios de seleção**

Fontes dos critérios de seleção: Documento do concurso

#### **5.1.11. Documentos do concurso**

Línguas em que os documentos do concurso estão oficialmente disponíveis: inglês

Línguas em que os documentos do concurso (ou as suas partes) estão oficiosamente disponíveis: inglês

Prazo para solicitar informações adicionais: 24/04/2026 15:00:00 (UTC+01:00) hora da Europa Central, hora de verão da Europa Ocidental

Endereço dos documentos do concurso: <https://www.etenders.gov.ie/epps/cft/listContractDocuments.do?resourceId=7885524>

#### **5.1.12. Condições do concurso**

##### **Condições de apresentação:**

Apresentação por via eletrónica: Necessário

Endereço para apresentação: <https://www.etenders.gov.ie/epps/cft/viewTenders.do?resourceId=7885524>

Línguas em que podem ser apresentadas as propostas ou pedidos de participação: inglês

Catálogo eletrónico: Não autorizado

Os proponentes podem apresentar mais do que uma proposta: Não autorizado

Prazo para a receção das propostas: 01/05/2026 15:00:00 (UTC+01:00) hora da Europa Central, hora de verão da Europa Ocidental

##### **Informações sobre a abertura pública:**

Data de abertura: 01/05/2026 15:30:00 (UTC+01:00) hora da Europa Central, hora de verão da Europa Ocidental

Local: <https://www.etenders.gov.ie/epps/cft/prepareViewCfTWS.do?resourceId=7885524>

##### **Condições do contrato:**

A execução do contrato tem de ser efetuada no âmbito de programas de emprego protegido: Não

#### **5.1.15. Técnicas**

##### **Acordo-quadro:**

Inexistência de acordo-quadro

##### **Informações sobre o sistema de aquisição dinâmico:**

Inexistência de sistema de aquisição dinâmico

#### **5.1.16. Informações adicionais, mediação e recurso**

Instância de recurso: The High Court of Ireland

Organização que fornece acesso fora de linha aos documentos do concurso: Medite Europe DAC

Organização que fornece mais informações sobre os procedimentos de recurso: The High Court of Ireland

Organização que recebe pedidos de participação: Medite Europe DAC

Organização responsável pelo tratamento das propostas: Medite Europe DAC

## **8. Organizações**

---

### **8.1. ORG-0001**

Nome oficial: Medite Europe DAC

Número de registo: 80984

Endereço postal: Redmondstown

Cidade: Clonmel

Código postal: E91V584

Subdivisão do país (NUTS): South-East (IE052)

País: Irlanda

Correio eletrónico: [John.Browne@mdfosb.com](mailto:John.Browne@mdfosb.com)

Telefone: 051831427

Perfil do adquirente: [www.etenders.gov.ie](http://www.etenders.gov.ie)

**Funções desta organização:**

Adquirente

Organização que fornece acesso fora de linha aos documentos do concurso

Organização que recebe pedidos de participação

Organização responsável pelo tratamento das propostas

**8.1. ORG-0002**

Nome oficial: The High Court of Ireland

Número de registo: The High Court of Ireland

Departamento: The High Court of Ireland

Endereço postal: Four Courts, Inns Quay, Dublin 7

Cidade: Dublin

Código postal: D07 WDX8

Subdivisão do país (NUTS): Dublin (IE061)

País: Irlanda

Correio eletrónico: [HighCourtCentralOffice@courts.ie](mailto:HighCourtCentralOffice@courts.ie)

Telefone: +353 1 8886000

**Funções desta organização:**

Instância de recurso

Organização que fornece mais informações sobre os procedimentos de recurso

**8.1. ORG-0003**

Nome oficial: European Dynamics S.A.

Número de registo: 002024901000

Departamento: European Dynamics S.A.

Cidade: Athens

Código postal: 15125

Subdivisão do país (NUTS): Βόρειος Τομέας Αθηνών (EL301)

País: Grécia

Correio eletrónico: [eproc-esender@eurodyn.com](mailto:eproc-esender@eurodyn.com)

Telefone: +30 2108094500

**Funções desta organização:**

TED eSender

## Informações sobre o anúncio

---

Identificador/versão do anúncio: 64611b95-7ea7-45c3-b367-8d428a2988f7 - 01

Tipo de formulário: Concurso

Tipo de anúncio: Anúncio de concurso — regime simplificado

Subtipo de anúncio: 20

Data de envio do anúncio: 10/04/2026 15:46:45 (UTC+01:00) hora da Europa Central, hora de verão da Europa Ocidental

Línguas em que o presente anúncio está oficialmente disponível: inglês

Número de publicação do anúncio: 252185-2026

N.º de edição do JO S: 72/2026

Data de publicação: 14/04/2026